

Site HOTO Report — DHK_X2727

Project Tiger · Dhaly Infratech → Alliance Computers Limited · Generated 07-Sep-2026 20:27 BD time

45%

FORM COMPLETION

0/0

CHECKLIST OK

3

OPEN SNAGS

3

TOTAL SNAGS

0

PHOTOS ATTACHED

Incomplete: the following expected fields were left blank in this submission — Site Type, BTS Type, Site Sharing, Site Photo, DG Meter Photo, Fuel Gauge Photo.

SITE & HANDOVER DETAILS

SITE CODE	DHK_X2727	ZONE	Sylhet
HOTO DATE	2026-09-02	DISTRICT	Narayanganj
HANDOVER ORG	Dhaly Infratech	TAKEOVER ORG	Alliance Computers Limited
HANDOVER PERSON	Md. Kabir Hossen	TAKEOVER PERSON	Md. Mahabur Rahman
HANDOVER PHONE	01958313020	TAKEOVER PHONE	01615220637
INSPECTED BY	Md. Mahabur Rahman	SECURITY GUARD	—
ACCESS KEY HANDED OVER	—	SITE TYPE	Not Filled
BTS TYPE	Not Filled		
SHARED WITH OPERATOR	Not Filled	SHARED OPERATOR NAME	—

GENERATOR INFORMATION

DG BRAND	Tempest	GENSET ASSET NO.	—
CAPACITY (KVA)	20	TYPE	—
FUEL TANK CAPACITY	2000	PRESENT RH	220.5
FUEL (NO WATER)	293 L	FUEL (TOTAL)	327 L
WATER AMOUNT	34 L	FUEL AMOUNT (WORD)	—
DG SITE TYPE	Standard	DG LOCKED AFTER FUELING	—
DG PRESENT STATUS	OK	GENSET ON ALARM	OK
BATTERY BRAND	—	BATTERY SERIAL	—
BATTERY AH	100	ENGINE SERIAL	—
ATS BRAND	—	ATS MODE	Auto
RH METER TYPE	—	LAST SERVICE DATE	2026-08-17
KEY TYPE	—	KEY STATUS — BTS	—
KEY STATUS — DG ROOM	—		

ACTIVE DG	—	CONNECTED FUEL TANKS	—
FAULTY/DISCONNECTED DG	—	FAULTY/DISCONNECTED TANKS	—



SNAGS FOUND (3)

SNAG #	SYSTEM	CATEGORY	COMPONENT	STATUS	OBSERVATIONS	ACTION	PHOTO
S-031	DG	DG - Mechanical/Fuel	Radiator	Faulty	DG Radiator mounting broken	Open	—
S-032	DG	DG - Controller/Electronics	Genset Alarm	Faulty	DG Run Alarm probably needs wiring	Open	—
S-033	DG	Structural/Civil Damage	DG Room Light	Faulty	DG Room wiring faulty	Open	—

DEFICIENCIES & SAFETY REMARKS

DG MAJOR DEFICIENCIES	—
SAFETY REMARKS	—
GENERAL REMARKS	Digitized from scanned paper HOTO checklist (Narsingdi zone backfill).

SITE PHOTOS

 Not Filled Site / Nameplate	 Not Filled DG RH / Meter	 Not Filled Fuel Gauge
--	---	--

Md. Kabir Hossen

Handed Over By · Dhaly Infratech
01958313020

Date: _____

Md. Mahabur Rahman

Taken Over By · Alliance Computers
Limited
01615220637

Date: _____

BL Concern · Name / Signature

Date: _____