

Site HOTO Report — DHK_G4393

Project Tiger · Dhaly Infratech → Alliance Computers Limited · Generated 07-Sep-2026 20:27 BD time

45%

FORM COMPLETION

0/0

CHECKLIST OK

4

OPEN SNAGS

4

TOTAL SNAGS

0

PHOTOS ATTACHED

Incomplete: the following expected fields were left blank in this submission — Site Type, BTS Type, Site Sharing, Site Photo, DG Meter Photo, Fuel Gauge Photo.

SITE & HANDOVER DETAILS

SITE CODE	DHK_G4393	ZONE	Sylhet
HOTO DATE	2026-09-02	DISTRICT	Narayanganj
HANDOVER ORG	Dhaly Infratech	TAKEOVER ORG	Alliance Computers Limited
HANDOVER PERSON	Md. Kabir Hossen	TAKEOVER PERSON	Md. Mahabur Rahman
HANDOVER PHONE	01958313020	TAKEOVER PHONE	01615220637
INSPECTED BY	Md. Mahabur Rahman	SECURITY GUARD	—
ACCESS KEY HANDED OVER	—	SITE TYPE	Not Filled
BTS TYPE	Not Filled		
SHARED WITH OPERATOR	Not Filled	SHARED OPERATOR NAME	—

GENERATOR INFORMATION

DG BRAND	Tempest	GENSET ASSET NO.	—
CAPACITY (KVA)	22	TYPE	—
FUEL TANK CAPACITY	1000	PRESENT RH	17424.33
FUEL (NO WATER)	251 L	FUEL (TOTAL)	295 L
WATER AMOUNT	44 L	FUEL AMOUNT (WORD)	—
DG SITE TYPE	Standard	DG LOCKED AFTER FUELING	—
DG PRESENT STATUS	OK	GENSET ON ALARM	OK
BATTERY BRAND	Lucas	BATTERY SERIAL	—
BATTERY AH	100	ENGINE SERIAL	—
ATS BRAND	Mets Energy	ATS MODE	Auto
RH METER TYPE	—	LAST SERVICE DATE	2026-06-19
KEY TYPE	—	KEY STATUS — BTS	—
KEY STATUS — DG ROOM	—		

ACTIVE DG	—	CONNECTED FUEL TANKS	—
FAULTY/DISCONNECTED DG	—	FAULTY/DISCONNECTED TANKS	—

SNAGS FOUND (4)

SNAG #	SYSTEM	CATEGORY	COMPONENT	STATUS	OBSERVATIONS	ACTION	PHOTO
S-034	DG	DG - Mechanical/Fuel	Fuel Pipe	Faulty	Injector over fuel pipe fault	Open	—
S-035	DG	Structural/Civil Damage	DG Room Light	Faulty	Faulty	Open	—
S-036	DG	Structural/Civil Damage	BTS Room Condition	Faulty	DG Room condition bad and poor	Open	—
S-037	DG	DG - Mechanical/Fuel	Fuel Tank	Faulty	DG Room fuel not properly kept	Open	—

DEFICIENCIES & SAFETY REMARKS

DG MAJOR DEFICIENCIES	—
SAFETY REMARKS	—
GENERAL REMARKS	Digitized from scanned paper HOTO checklist (Narsingdi zone backfill).

SITE PHOTOS

No Photo Not Filled Site / Nameplate	No Photo Not Filled DG RH / Meter	No Photo Not Filled Fuel Gauge
---	--	---

Md. Kabir Hossen Handed Over By · Dhaly Infratech 01958313020 Date: _____	Md. Mahabur Rahman Taken Over By · Alliance Computers Limited 01615220637 Date: _____	BL Concern · Name / Signature Date: _____
--	--	---