

Site HOTO Report — SYL_X0083

Project Tiger · Dhaly Infratech → Alliance Computers Limited · Generated 07-Sep-2026 20:53 BD time

100%

FORM COMPLETION

0/0

CHECKLIST OK

0

OPEN SNAGS

0

TOTAL SNAGS

3

PHOTOS ATTACHED

SITE & HANDOVER DETAILS

SITE CODE	SYL_X0083	ZONE	Sylhet
HOTO DATE	2026-09-07	DISTRICT	Habiganj
HANDOVER ORG	Dhaly Infratech	TAKEOVER ORG	Alliance Computers Limited
HANDOVER PERSON	Syed	TAKEOVER PERSON	sourav
HANDOVER PHONE	01716332171	TAKEOVER PHONE	01847426870
INSPECTED BY	sourov sarkar	SECURITY GUARD	Yes
ACCESS KEY HANDED OVER	—	SITE TYPE	GFT
BTS TYPE	Outdoor		
SHARED WITH OPERATOR	Yes	SHARED OPERATOR NAME	—

GENERATOR INFORMATION

DG BRAND	FG Wilson	GENSET ASSET NO.	—
CAPACITY (KVA)	22	TYPE	—
FUEL TANK CAPACITY	2000	PRESENT RH	—
FUEL (NO WATER)	386 L	FUEL (TOTAL)	431 L
WATER AMOUNT	45 L	FUEL AMOUNT (WORD)	Four Hundred Thirty One Liters
DG SITE TYPE	Standard	DG LOCKED AFTER FUELING	Yes
DG PRESENT STATUS	OK	GENSET ON ALARM	—
BATTERY BRAND	Lucas	BATTERY SERIAL	—
BATTERY AH	100	ENGINE SERIAL	—
ATS BRAND	Local	ATS MODE	Auto
RH METER TYPE	Digital from controller	LAST SERVICE DATE	—
KEY TYPE	—	KEY STATUS — BTS	—
KEY STATUS — DG ROOM	—		
ACTIVE DG	1	CONNECTED FUEL TANKS	2

FAULTY/DISCONNECTED DG	—	FAULTY/DISCONNECTED TANKS	—
------------------------	---	---------------------------	---

CONNECTED GENERATOR CHECKLIST & READINGS

ITEM	VALUE	ITEM	VALUE
Earth Connection OK	Yes	Phase	3 Phase
Engine Brand	Perkins		


SNAGS FOUND (0)

No snags logged for this visit.

DEFICIENCIES & SAFETY REMARKS

DG MAJOR DEFICIENCIES	—
SAFETY REMARKS	—
GENERAL REMARKS	—

SITE PHOTOS

 SYL_X0083 - Project Tiger HOTO Site / Nameplate Photo 07-Sep-2026 18:16 BD time Site / Nameplate	 SYL_X0083 - Project Tiger HOTO DG RH / Meter Photo 07-Sep-2026 18:16 BD time DG RH / Meter	 SYL_X0083 - Project Tiger HOTO Fuel Gauge Photo 07-Sep-2026 18:16 BD time Fuel Gauge
---	---	---

Syed Handed Over By · Dhaly Infratech 01716332171 Date: _____	sourav Taken Over By · Alliance Computers Limited 01847426870 Date: _____	BL Concern · Name / Signature Date: _____
---	--	--

APPENDIX — PHOTO EVIDENCE (3)

Full-size reference photos for SYL_X0083, grouped by type and numbered for cross-reference against the tables above.

REQUIRED SITE PHOTOS (3)



Photo 1 — Site / Nameplate



Photo 2 — DG RH / Meter



Photo 3 — Fuel Gauge